



How to solve the problem:

In plant automation it is sensible to secure all movements with a time-out timer. The solution of lesson 3 is expanded with forks and time-out transitions. This causes the system to go into an error step, if the limit switch is not reached before the time-out transition becomes true. The error step can be left with the RESET-Transition, controlled by the Reset-Button on the user interface.